

Government of Andhra Pradesh
A.P. State Disaster Response and Fire Services Department

Periodical Renewal Fire Certificate

From:
 District Disaster Response & Fire Officer
 Andhra Pradesh, Prakasam

To:
 District Fire officer, Prakasam district,

File No: 28686/PRK/DFO/2025, Date:17/04/2026
Occupancy NoC RC Number: 943/A3/2014, Dt 11-06-2021

Sir,

Sub: Andhra Pradesh State Disaster Response and Fire Services Department - Periodical Fire Certificate to the existing Non Multi Storeyed Building of **Kamala High school, represented by P Pavan Kumar, Kamala High School, Ramachandrapuram (p) Krishna puram(V) Markapur-523316** - Regarding.

- Ref:
1. G.O.Ms.NO.218 Home (Prisons & Fire) Department, Dated.22-12-2023
 2. This Office Delegation of Powers Rc.No.3350/Audit/NOC/2012, Dated.02-05-2023.
 3. This Office NOC for Occupancy Rc No. 943/A3/2014, Dt 11-06-2021, Dt.11/06/2021
 4. Renewal NOC For Occupancy 943/A3/2014, Dt 11-06-2021, Dt.07/10/2025
 5. Online Application for Renewal NOC of P Pavan Kumar, Kamala High School, Ramachandrapuram (p) Krishna puram(V) Markapur-523316 - Inspection report called for Regarding.
 6. Online Inspection Report submitted by Officers of this Department on 16-04-2026.

-- X --

The Management of Kamala High school, represented by P Pavan Kumar, Kamala High School, Ramachandrapuram (p) Krishna puram(V) Markapur-523316 has requested to issue Periodical Fire Certificate duly remitting the Fire Precautionary fee for Rs.24161/- vide challan No. 90137535012025, Dated 07/11/2025 at ONLINE, ONLINE.

Kamala High school

1. This certificate is being issued as per G.O.Ms.No:218,Home(Prisons & Fire),Dt:22-12-2023
2. The No Objection Certificate for Occupancy was issued vide reference cited (3) and the Management has also obtained Periodical Renewal Fire Certificate for vide reference 4th cited to the existing Non Multi Storeyed Building.
3. The Officers of the department have recommended to issue The Periodical Renewal Fire Certificate P **Pavan Kumar Kamala High School, Ramachandrapuram (p) Krishna puram(V) Markapur-523316**, subject to the following conditions.

Sl	As Builder	As Occupant	As Security Personnel
----	------------	-------------	-----------------------

1	All the fire protection arrangements shall be maintained in good condition as seen during inspection.	All the escape/exit routes shall not be kept locked/blocked or encroached	All the occupants must know the correct method of operation of the fire fighting system installed.
2	Any loss of life or property due to non-functioning of fire safety measures and other installations shall be the responsibilities of the management.	All occupants shall be trained to operate the fire safety equipments during emergency.	Mock drills should be conducted once in 3 months for initial two years. Thereafter, once in every 6 months.
3	Addition / alteration, if any in the building may be verified by building authority.	Mock drills should be conducted once in 3 months for initial two years. Thereafter, once in every 6 months.	All security personnel shall be trained to operate the fire safety equipments during emergency.
4	This is Only for Fire Safety Point of View.	Raise the alarm if the fire cannot be controlled; Evacuate the area completely at once with nearest safe exit.	Attack the fire using available fire equipment only if you feel capable of controlling. If not, take all steps to isolate the area by closing doors and windows.

The applicant/management must train 40% of their total work force on 3 days Basic Firefighting Course under AP Fire Services and Civil Defence Training Institute, Sattenapalli or Regional Training Centres of the Department.

4. This Periodical Renewal Fire Certificate is valid from 04/12/2026 to 04/12/2031.

5. The Responsibility/liability of the owner/occupier or both to maintain Fire safety measures in good condition in all times, in accordance with AP Fire safety Act 1999 and Rules, 2006.

6. Challan Info:

Challan Number	Challan Date	Challan Amount
90137535012025	2025-11-07	24161
11011053382026	2026-04-10	96650

The following deficiencies/suggestions are identified by the officers of the department and needs to be attended to by the management.

The Managment has Provided The Fire Safety Measures as Per National Building Crde Of India-2016.The Fire Fighting Equipment were Tested during The inspection time Randomly,The Fire Fighting Equipment Were in good Working Condition.The Managment has Paid Challan For One Year Of Renewal Noc at The Time Of before Submitting The Online application and at The Time Of inspection The Managment has Paid Challan For Onther Four Years For Rs.96,650.00 (i.e) Total Challan Paid For 05 Years Of Renewal Noc

[Handwritten signature]

"Safe School, Safe Hospital & Fire Safety Society-Together for Fire Prevention"

"सुरक्षित विद्यालय, सुरक्षित अस्पताल एवं अग्नि सुरक्षा के प्रति जागरूक समाज आग की रोकथाम के लिए एक साथ"
"సురక్షిత పాఠశాలలు, సురక్షిత మైన ఆసుపత్రులు మరియు అగ్నిమాపక భద్రతపై సమూహ ఉన్న సమాజం
మంటలను నివారించడానికి కలిసి పనిచేస్తాయి."

Your Sincerely,



[Signature]
District Disaster Response & Fire Officer,
Prakasam District

In case of emergency, please call 101 or 08596-222099 or 9963733293

Copy to Management P Pavan Kumar, P Pavan Kumar
Copy to Assistant District Fire Officer Concerned
Copy to Station Fire Officer Concerned